

Evidence of Performance

Air permeability, Watertightness, Resistance to wind load



Test Report

No. 16-000661-PR01

(PB-A01-02-en-01)

Client	Serbial d.o.o. Resavska bb 35211 Sedlare Serbia
Product	Double combined side-hung & tilt turn window with opening meeting stile
Designation	System designation: *)
Performance-relevant product details	Material: Aluminium profiles with thermal break
Overall dimensions (W x H)	1,620 mm x 2,400 mm
Special features	*) According to the client the profiles are from the System Reynaers CS 86 HI – HV by the company Reynaers GmbH. A sampling report dated 03.03.2016 has been presented to ift-Rosenheim.

Basis

EN 14351-1:2006+A1:2010

Test standard/s:

EN 1026:2000-06

EN 1027:2000-06

EN 12211:2000-06

Correspond/s to the national standard/s (e.g. DIN EN)

Representation



Results

Air permeability according to EN 12207:1999-11



Class 4

Watertightness according to EN 12208:1999-11



Class 4A

Resistance to wind load according to EN 12210:1999-11/AC:2002-08



Class C2 / B2

Instructions for use

The results obtained can be used by the manufacturer as the basis for the manufacturer type testing test report summary. Observe the specifications set out by the applicable product standard.

Validity

The data and results refer solely to the tested and described specimen. Classification remains valid as long as the product and the above basis remain unchanged. The results can be extrapolated under the manufacturer's own liability subject to observance of the relevant specifications set out by the applicable product standard. This test/evaluation does not allow any statement to be made on any further characteristics regarding performance and quality of the construction presented; in particular the effects of weathering and ageing were not taken into account.

Notes on publication

The ift-Guidance Sheet "Advertising with ift test documents" applies. The cover sheet can be used as an abstract.

The report contains a total of 26 pages.

ift Rosenheim

14.04.2016

Thomas Stefan, Dipl.-Ing. (FH)
Head of Testing Department
Construction Product Testing

Thomas Krichbaumer
Operating Testing Officer
Construction Product Testing