

Evidence of Performance

Air permeability, Watertightness, Resistance to wind load



Test Report

No 16-002692-PR01

(PB-A01-02-en-01)

Client	Serbial d.o.o. Resavska bb 35211 Sedlare Serbia
Product	Single tilt and turn casement door
Designation	System designation: *)
Performance-relevant product details	Material: Aluminium profiles with thermal break
Overall dimensions (W x H)	1,100 mm x 2,660 mm
Special features	*) According to the client the profiles are from the company SCHÜCO International KG from the system SCHÜCO AWS / ADS 6. A sampling report dated 15.08.2016 has been provided to the ift Rosenheim. According to the client the installed, integrated opening limiter is no safety device in the sense of EN 14351-1. **) Variant 1: Test with two nozzle lines. ***) Variant 2: Test with one nozzle line. This result is applicable for casement doors ≤ 2,500 mm

Basis

EN 14351-1:2006+A1:2010

Test standard/s:

EN 1026:2000-06

EN 1027:2000-06

EN 12211:2000-06

Correspond/s to the national standard/s (e.g. DIN EN)

Representation



Results

Air permeability according to EN 12207:1999-11



Class 4

Watertightness according to EN 12208:1999-11



Variant 1 **)

Class E750

Variant 2 ***)

Class E900

Resistance to wind load

according to EN 12210:1999-11/AC:2002-08



Class C5 / B5

ift Rosenheim

23.09.2016

Thomas Stefan, Dipl.-Ing. (FH)
Head of Testing Department
Construction Product Testing

Thomas Krichbaumer
operating testing officer
Construction Product Testing

Instructions for use

The manufacturer is allowed to use the results obtained for preparing a Declaration of Performance in accordance with the Construction Products Regulation 305/2011/EC. Observe the specifications set out by the applicable product standard.

Validity

The data and results refer solely to the tested and described specimen. Classification remains valid as long as the product and the above basis remain unchanged. The results can be extrapolated under the manufacturer's own liability subject to observance of the relevant specifications set out by the applicable product standard. This test/evaluation does not allow any statement to be made on any further characteristics regarding performance and quality of the construction presented; in particular the effects of weathering and ageing were not taken into account.

Notes on publication

The ift-Guidance Sheet "Advertising with ift test documents" applies. The cover sheet can be used as an abstract.

The report contains a total of 24 pages.